



Typical Analysis

Westbuild Mastic Adhesive

VOC Content Test Certificate

Manufacturer: Westbuild Products Pty Ltd

Product: Westbuild Mastic Adhesive

Test Method: ASTM D3690-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Date Tested: May 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Westbuild Mastic Adhesive
General Purpose Adhesives and Sealants: 50 grams per Litre	<1 grams per Litre as VOC content per material
We hereby certify that Westbuild Mastic Adhesive is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia.	

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ ACA, AIRAH, FMA
Managing Director and Principal Consultant

Tuan Duong
BE (Chem. Eng.)
Consultant

Luke Morley
BSc (Tech)
Consultant